

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015104  
**DATE:** 12/01/2020  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "Auraline "</b> <b>Composite Patio Door Transom</b> <b>(w/Nail Fin or Thru-Frame)</b>  Configuration: O Glazing: Insulating Glass (Tempered)  Frame: W-3661mm(144") H-1219mm(48") DLO: W-3480mm(137") H-1022mm(40.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class LC-PG35 3661 x 1219 (144 x 48)-TR</b> <b>Design Pressure: ±1680 Pa (±35 psf)</b> <b>Positive Design Pressure: 1680 Pa (35 psf)</b> <b>Negative Design Pressure: 1920 Pa (40 psf)</b> <b>Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf)</b>

Product Tested By: Intertek, PLC  
Report No: L5303.01-301-47  
Expiration Date: **October 31, 2030**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shu", written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122