

# Hallmark® Certificate of Conformance and License (CCL)




Pella Corporation  
102 Main Street  
Pella, IA 50219

Mfr ID: 411  
For more Information visit [www.amscert.com](http://www.amscert.com)  
Website: [www.pella.com](http://www.pella.com)  
TEL: 641-621-6096

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
411-H-1514.13	Impervia 2 Sliding Patio Door	101/I.S.2/A440-11	Class LC-PG35; Size Tested 2419mm (95.25 in) x 2426mm (95.5 in) Type-SD; Water Test Press 510Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	2419mm (95.25 in)	2426mm (95.5 in)	ESP035050P.7	5/3/2021	3/31/2031
411-H-1514.14	Impervia 2 Sliding Patio Door	101/I.S.2/A440-17	Class LC-PG35; Size Tested 2419mm (95.25 in) x 2426mm (95.5 in) Type-SD; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	2419mm (95.25 in)	2426mm (95.5 in)	ESP035050P.7	5/3/2021	3/31/2031

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:  
Window and Door Manufacturers Assoc  
330 N. Wabash Avenue, Suite 2000  
Chicago, IL 60611  
TEL (312)673-4828 [www.wdma.com](http://www.wdma.com)

Program Administrator:  
Administrative Management Systems, Inc.  
PO Box 730, 205 West Main  
Sackets Harbor, NY 13685  
TEL (315)646-2234 [staff@amscert.com](mailto:staff@amscert.com)