

Hallmark® Certificate of Conformance and License (CCL)




ProVia LLC
2150 State Route 39
Sugarcreek, OH 44681

Mfr ID: 462
For more Information visit www.amscert.com
Website:
TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
462-H-009.00	Aspect/Endure Casement	101/I.S.2/A440-11	Class R-PG50; Size Tested 36" x 75" Type-C; DP +50/-50 psf; Water Test Press 540Pa (11.28psf)	36"	75"	e1051.03-501-47 Specimen #1	6/16/2021	11/13/2024

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  **John McFee, VP of Certification Programs, WDMA Hallmark**

By:  **Lucas L. Wenzel, Authorized Representative, AMS**

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com