

# Hallmark® Certificate of Conformance and License (CCL)




ProVia LLC  
2150 State Route 39  
Sugarcreek, OH 44681

Mfr ID: 462  
For more Information visit [www.amscert.com](http://www.amscert.com)  
Website:  
TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
462-H-007.00	Endure/Aspect Picture Window	101/I.S.2/A440-11	Class CW-PG50; Size Tested 60" x 63" Type-FW; DP +50/-50 psf; Water Test Press 580Pa (12.11psf)	60"	63"	d9601.04-501-47 Specimen#4	6/16/2021	11/17/2024

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  **John McFee, VP of Certification Programs, WDMA Hallmark**

By:  **Lucas L. Wenzel, Authorized Representative, AMS**

Program Sponsor:  
Window and Door Manufacturers Assoc  
330 N. Wabash Avenue, Suite 2000  
Chicago, IL 60611  
TEL (312)673-4828 [www.wdma.com](http://www.wdma.com)

Program Administrator:  
Administrative Management Systems, Inc.  
PO Box 730, 205 West Main  
Sackets Harbor, NY 13685  
TEL (315)646-2234 [staff@amscert.com](mailto:staff@amscert.com)