



**AAMA CERTIFICATION PROGRAM**  
An FGIA Product Certification Program



**AUTHORIZATION FOR PRODUCT CERTIFICATION**

**Simonton Windows**  
1 Cochrane Dr.  
Pensboro, WV 26415

**Attn: Tina Seese**

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED		
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11 R-PG40-2419x895 (95x35)-FW</b>	<b>AAMA 506</b>			
COMPANY AND CODE	Missile Level: <b>C</b> Rating: <b>+40/-40, 95x35</b> Wind Zone: <b>2</b>	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED
<b>Simonton Windows Code: SIM</b>	Rating above conforms to the requirements of: <b>ASTM E1886 and E1996</b>	<b>19773</b>	<b>15-15/15-16 FIXED (PVC)(O)(OG) (INS TEMP/0.060" PVB LAM GL) (MODIF)(ASTM)</b>	<b>FRAME</b> <b>2419 mm x 895 mm (7'11" x 2'11")</b>

This Certification will expire **June 26, 2025** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:  
**PRI Construction Materials Technologies, LLC**  
Report No: **SIMO-011-03-01 & -03**  
Date of Reports: **July 24, 2015**

Missile Impact Test & Report By:  
**National Certified Testing Laboratories**  
Report No: **NCTL-110-24401-1**  
Date of Report: **June 23, 2021**

Evaluated for Certification: **July 22, 2021**

Associated Laboratories, Inc.

Authorized for Certification: **July 22, 2021**

Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)