

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013359.01-R1  
DATE: 03/05/2019  
CERTIFICATION PROGRAM: Structural  
COMPANY: All Seasons  
CODE: 353-2  
REVISION DATE: 02/21/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>All Seasons Commercial Division, Inc.</b> <b>400 Ambassador Row</b> <b>Longview, TX 75604</b>	<b>Series "8065" Thermally Broken</b> <b>Aluminum Sliding Glass Door</b>  Configuration: OX Glazing: Insulating Glass (Tempered) Frame: W-3124mm(123") H-2413mm(95") Panel: W-1549mm(61") H-2354mm(92.68") DLO: W-1400mm(55.13") H-2203mm(86.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class AW-PG50 3124 x 2413 (123 x 95)-SD</b> <b>Design Pressure: ±2400 Pa (50 psf)</b> Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)

Product Tested By: Construction Consulting Laboratory, International  
Report No: CCLI 18-0152  
Expiration Date: **October 31, 2028**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "MD", written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)