

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006785.01-R4
DATE: 11/06/2006
CERTIFICATION PROGRAM: Structural
COMPANY: Quaker
CODE: 031-1
REVISION DATE: 09/16/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products 504 Highway 63 South Freeburg, MO 65035	Series "V 200 Manchester" Vinyl Single Hung Window w/Reinforcement Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1016mm(40") H-1600mm(63") Sash: W-940mm(37") H-770mm(30.3")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05	H-R35 1016 x 1600 (40 x 63) Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)

Product Tested By: Architectural Testing, Inc.
Report No: 67699.02-801-47/67699.01-801-47
Expiration Date: **October 31, 2030**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122