

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015436-R1
DATE: 09/27/2021
CERTIFICATION PROGRAM: Structural
COMPANY: Quaker
CODE: 031-1
REVISION DATE: 10/14/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products 504 Highway 63 South Freeburg, MO 65035	Series "V700" Vinyl Casement Window Configuration: X Glazing: IG-Int-Laminate-1/8" Annealed Glass/ 0.090" PVB by Kuraray/1/8" Annealed Glass/ Ext-1/8" Annealed Glass Frame: W-914mm(36") H-1829mm(72") Sash: W-892mm(35.13") H-1807mm(71.13") DLO: W-740mm(29.13") H-1654mm(65.13")

SPECIFICATION	PRODUCT RATING
AAMA 506-16 AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-13a/19 ASTM E1996-17/20	Class CW-PG50 914 x 1829 (36 x 72)-C Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Wind Zone 4-Missile Level D Large Missile Impact Rated

Product Tested By: Intertek, LLC
Report No: H4476.01-801-44-r5/M2439.01-201-44-r2/F9424.01-801-47
Expiration Date: **April 30, 2029**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122