

# Hallmark® Certificate of Conformance and License (CCL)




Marvin  
PO Box 100  
401 State Ave N.  
401 State Ave N.  
Warroad, MN 56763

Mfr ID: 407  
For more Information visit [www.amscert.com](http://www.amscert.com)  
Website: [www.marvin.com](http://www.marvin.com)  
TEL: 218-386-1430

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
407-H-1161.08	Ultimate Inswing Door 2.25 IZ3 Stat ( 3" rail & stile ) and Ultimate Inswing French Door 2.25 Sidelite G2 IZ3 3680 Stationary	101/I.S.2/A440-11	Class LC-PG65; Size Tested 1103 (43-7/16") x 2498 (98") Type-FD; DP +65/-65 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	1103 (43-7/16")	2498 (98")	M7280.01-201-47	2/18/2022	8/18/2031
407-H-1161.09	Ultimate Inswing Door 2.25 IZ3 Stat ( 3" rail & stile ) and Ultimate Inswing French Door 2.25 Sidelite G2 IZ3 3680 Stationary	101/I.S.2/A440-17	Class LC-PG65; Size Tested 1103 (43-7/16") x 2498 (98") Type-FD; DP +65/-65 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	1103 (43-7/16")	2498 (98")	M7280.01-201-47	2/18/2022	8/18/2031
407-H-1161.10	Ultimate Inswing Door 2.25 IZ3 Stat ( 3" rail & stile ) and Ultimate Inswing French Door 2.25 Sidelite G2 IZ3 3680 Stationary	ASTM E-1996 17/ASTM E-1886 13a	DP +65/-65 psf, Missile D, Wind Zone 3	1103 (43-7/16")	2498 (98")	M7280.02-201-47 R2	2/18/2022	8/20/2031

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:  
Window and Door Manufacturers Assoc  
330 N. Wabash Avenue, Suite 2000  
Chicago, IL 60611  
TEL (312)673-4828 [www.wdma.com](http://www.wdma.com)

Program Administrator:  
Administrative Management Systems, Inc.  
PO Box 730, 205 West Main  
Sackets Harbor, NY 13685  
TEL (315)646-2234 [staff@amscert.com](mailto:staff@amscert.com)