

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015832.07-R1  
**DATE:** 07/25/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Ply Gem  
**CODE:** 1408-1  
**REVISION DATE:** 08/03/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b>  <b>Simonton Windows</b>  <b>520 Weston Parkway, Suite 300</b>  <b>Cary, NC 27513</b>	<p style="text-align: center;"><b>Series “Ply Gem Perspective/ Simonton MaxView”</b></p> <p style="text-align: center;"><b>Vinyl Sliding Glass Door</b></p> <p style="text-align: center;"><b>(3-Track w/Interior Pocket)</b></p> <p style="text-align: center;">Configuration: XXXX                      Glazing: IG-3/16" Tempered Glass/1/8" Heat Strengthened                      Glass/0.090" Eastman Saflex PVB Interlayer/1/8" Heat Strengthened                      Glass</p> <p>Frame: W-4718mm(185.75") H-3035mm(119.5")</p> <p>Panel: W-1248mm(49.13") H-2975mm(117.13")</p> <p>DLO: W-1019mm(40.13") H-2145mm(108.06")</p>

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>ASTM E1886-12/19</b> <b>ASTM E1996-17/20</b>	<b>Class LC-PG60 4718 x 3035 (186 x 120)-SD</b> <b>Design Pressure: ±2880 Pa (±60 psf)</b> <b>Positive Design Pressure: 2880 Pa (60 psf)</b> <b>Negative Design Pressure: 3120 Pa (65 psf)</b> Water Penetration Resistance Test Pressure: 440 Pa (9.2 psf) <b>Wind Zone III - Missile Level D</b>

Product Tested By: Molimo Architectural Product Testing  
 Report No: 11835.14-106-11/W-2073  
 Expiration Date: **March 31, 2027**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
 MANAGEMENT INSTITUTE, INC.**  
 4794 George Washington Memorial Highway  
 Hayes, VA 23072  
 Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)