

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015832.23
DATE: 07/30/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group Simonton Windows 5020 Weston Parkway, Suite 300 Cary, NC 27513	Series "Ply Gem Perspective/ Simonton MaxView" Vinyl Sliding Glass Door (3-Track w/Exterior Pocket) Configuration: XXX-XXXXP Glazing: Insulating Glass (Tempered) Frame: W-7126mm(280.56") H-3035mm(119.5") Panel: W-1248mm(49.13") H-2974mm(117.06") DLO: W-1019mm(40.13") H-2745mm(108.06")

SPECIFICATION	PRODUCT RATING
TAS 202-94	Design Pressure: ±2880 Pa (±60 psf) Positive Design Pressure: 2880 Pa (60 psf) Negative Design Pressure: 3120 Pa (65 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.2 psf)

Product Tested By: Molimo Architectural Product Testing
Report No: 11835.19-106-11/W-2077
Expiration Date: **March 31, 2027**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com