

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015444-R1
DATE: 09/30/2021
CERTIFICATION PROGRAM: Structural
COMPANY: ProVia Door
CODE: 1212-1
REVISION DATE: 04/11/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ProVia, LLC 2150 State Route 39 Sugarcreek, OH 44681	20 Gauge Steel 3-Lite Inswing Patio Door System (w/Plugged Trim & Single Point Lock) Configuration: OXO Glazing: Insulated Glass (Tempered) Frame: W-2788mm(109.75") H-2481mm(97.69") Panel: W-908mm(35.75") H-2411mm(94.94") DLO: W-537mm(21.13") H-2013mm(79.25")

SPECIFICATION	PRODUCT RATING
ASTM E283-04(2012) ASTM E330/E330M-14	Design Pressure: ±1920 Pa (±40 psf) Positive Design Pressure: 1920 Pa (40 psf) Negative Design Pressure: 2160 Pa (45 psf)

Product Tested By: Intertek, PLC
Report No: M4271.01-501-47/W-2024
Expiration Date: June 30, 2025

Administrator's Signature: _____

**NATIONAL ACCREDITATION &
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com