

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015444.02-R1  
DATE: 09/30/2021  
CERTIFICATION PROGRAM: Structural  
COMPANY: ProVia Door  
CODE: 1212-1  
REVISION DATE: 04/11/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>ProVia, LLC</b> <b>2150 State Route 39</b> <b>Sugarcreek, OH 44681</b>	<b>20 Gauge Steel Full-Lite</b> <b>Inswing Patio Door System</b> <b>(w/Single Point Lock)</b>  Configuration: OXO Glazing: IG-1/8" Tempered Glass/1/8" Annealed Glass/0.090" Saflex PVB Interlayer/1/8" Annealed Glass  Frame: W-2788mm(109.75") H-2481mm(97.69") Panel: W-908mm(35.75") H-2411mm(94.94") DLO: W-533mm(21") H-2007mm(79")

SPECIFICATION	PRODUCT RATING
<b>ASTM E1886-13a</b> <b>ASTM E1996-14a</b>	<b>Design Pressure: ±2400 Pa (±50 psf)</b> <b>Wind Zone 3 - Missile Level D</b>

Product Tested By: Intertek, PLC  
Report No: M4361.01-501-47/W-2024  
Expiration Date: **June 30, 2025**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

**NATIONAL ACCREDITATION &  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

[nami@namiinc.com](mailto:nami@namiinc.com)