

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC. Administrative Management Systems, Inc.

VELUX America LLC 450 Old Brickyard Rd PO Box 5001 PO Box 5001 Greenwood, SC 29649 *Mfr ID:* 426

For more Information visit www.amscert.com

Website: www.veluxusa.com

TEL: 864-941-5309

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
426-H-731.64	Dynamic Polycarbonate Domes (Impact), CMD2/DMD2, 4' x 8', 0.150" smooth poly over 0.118" smooth poly	101/I.S.2/A440-17	Class PG-PG80; Size Tested 1327mm x 2546mm Type-SKP; DP +80/-80 psf; Water Test Press 720Pa (15.04psf); Can. Air Infil/Exfil. Level=Fixed	1327mm	2546mm	NCTL-210-4240-01A	4/5/2022	1/28/2032
426-H-731.65	Dynamic Polycarbonate Domes (Impact), CMD2/DMD2, 4' x 8', 0.150" smooth poly over 0.118" smooth poly	101/I.S.2/A440-11	Class PG-PG80; Size Tested 1327mm x 2546mm Type-SKP; DP +80/-80 psf; Water Test Press 720Pa (15.04psf); Can. Air Infil/Exfil. Level=Fixed	1327mm	2546mm	NCTL-210-4240-01A	4/5/2022	1/28/2032
426-H-731.75	Dynamic Polycarbonate Domes (Impact), CMD2/DMD2, 4' x 8', 0.150" smooth poly over 0.118" smooth poly	TAS 201/202/203-94	DP +55/-60 psf, Large Missile	1327mm	2546mm	NCTL-210-4240-01B	8/4/2022	1/28/2032

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By: John McFee, VP of Certification Programs, WDMA Hallmark

By: Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor: Window and Door Manufacturers Assoc 330 N. Wabash Avenue, Suite 2000 Chicago, IL 60611

TEL (312)673-4828 www.wdma.com

Program Administrator: Administrative Management Systems, Inc. PO Box 730, 205 West Main Sackets Harbor, NY 13685 TEL (315)646-2234 staff@amscert.com

WD-20 5/26/2016 JGK Thursday, September 1, 2022 Page 1