

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015717-R1  
**DATE:** 01/12/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** All Seasons  
**CODE:** 353-2  
**REVISION DATE:** 02/21/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>All Seasons Commercial Division, Inc.</b> <b>400 Ambassador Row</b> <b>Longview, TX 75604</b>	<b>Series "E3250"</b> <b>Aluminum Project-Out Awning Window</b>  (w/ or w/o Receptor)  Configuration: X Glazing: IG-1/4" Annealed Glass/1/8" Annealed Glass/0.090" Saflex PVB Interlayer/1/8" Annealed Glass/ Frame: W-1372mm(54") H-1626mm(64") w/Receptor: W-1495mm(58.88") H-1710mm(67.31") Vent: W-1327mm(52.25") H-1588mm(62.5") DLO: W-1200mm(47.25") H-1454mm(57.25")

SPECIFICATION	PRODUCT RATING
<b>AAMA-506-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>ASTM E1886-13a/E1996-14a</b>	<b>Class CW-PG60 1371 x 1625 (54 x 64)-AP</b> <b>Design Pressure: ±2880 Pa (60 psf)</b> <b>Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)</b> <b>Wind Zone 4-Missile Level D</b>

Product Tested By: Construction Consulting Laboratory  
Report No: CCL 20-070  
Expiration Date: May 31, 2028

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023