

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014148.03-R1
DATE: 09/17/2020
CERTIFICATION PROGRAM: Structural
COMPANY: All Seasons
CODE: 353-2
REVISION DATE: 01/12/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|---|
| All Seasons Window & Door Mfg., Inc. 400 Ambassador Row Longview, Texas 75604 | Series "E3250" Aluminum Fixed Window (w/Fixed or Receptor Frame) Configuration: O Glazing: IG-1/4" Annealed Glass/1/8" Annealed Glass/0.090" Eastman Saflex PVB Interlayer/1/8" Annealed Glass Frame: W-1219mm(48") H-2438mm(96") DLO: W-1118mm(44") H-2337mm(92") |

| SPECIFICATION | PRODUCT RATING |
|--|--|
| ASTM E330-14 ASTM E1886-13a/E1996-14a | Design Pressure: ±3120 Pa (±60 psf) Wind Zone 4 - Missile Level D |

Product Tested By: Construction Consulting Laboratory, International
Report No: CCLI 19-132
Expiration Date: July 31, 2027

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com