

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014507.14-R1
DATE: 04/11/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Quaker
CODE: 031-1
REVISION DATE: 05/31/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products 504 Highway 63 South Freeburg, MO 65035	Series "C600/C605 Two Tone" Aluminum Fixed Window Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1524mm(60") H-2514mm(99") DLO: W-1443mm(56.81") H-2433mm(95.81")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class AW-PG100 1524 x 2514 (60 x 99)-FW Design Pressure: ±4800 Pa (±100 psf) Water Penetration Resistance Test Pressure: 720 Pa (15 psf)

Product Tested By: Intertek - Fridley, MN
Report No: M3439.01-201-47-R1/W-2068
Expiration Date: April 30, 2027

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com