

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014507.15-R1  
DATE: 03/09/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: Quaker  
CODE: 031-1  
REVISION DATE: 02/01/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Quaker Window Products</b> <b>504 Highway 63 South</b> <b>Freeburg, MO 65035</b>	<b>Series "C700/C705 One Tone"</b> <b>Aluminum Fixed Window</b>  Configuration: O Glazing: IG-1/4" Tempered Glass/1/8" Annealed Glass/0.090" Kuraray SG Interlayer/1/8" Annealed Glass  Frame: W-1524mm(60") H-2515mm(99")  DLO: W-1443mm(56.81") H-2434mm(95.81")

SPECIFICATION	PRODUCT RATING
<b>AAMA 506-16</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>ASTM E331-00(2016)(2023)</b> <b>ASTM E1886-13/19</b> <b>ASTM E1996-17/20</b>	<b>Class AW-PG60 1524 x 2515 (60 x 99)-FW</b> <b>Design Pressure: ±2873 Pa (±60 psf)</b> <b>Water Penetration Resistance Test Pressure: 720 Pa (15 psf)</b> <b>Wind Zone 3 - Missile Level D</b>

Product Tested By: Intertek, PLC  
Report No: P6494.01-550-44/M3439.01-201-47/W-2068  
Expiration Date: March 31, 2027

Administrator's Signature: 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)