

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011662-R1  
**DATE:** 09/06/2013  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1  
**REVISION DATE:** 06/10/2017

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS  | PRODUCT DESCRIPTION   |
|---|---|
| <b>JELD-WEN</b><br><br><b>3737 Lakeport Boulevard</b><br><br><b>Klamath Falls, OR 97601</b> | <b>"8700F Premium Atlantic Vinyl<br/>Stationary Casement Window"</b><br><br><b>Vinyl Fixed Window</b><br><br><b>w/Fin or Flange Installation</b><br><br>Configuration: O<br>Glazing: IG-3/16" Annealed Glass/Laminate-1/8"<br>Annealed Glass/0.090" DuPont SGP Interlayer/1/8"<br>Annealed Glass<br><br>Frame: W-1206mm(47.50") H-1816mm(71.50")<br><br>Vent: W-1168mm(46.00") H-1778mm(70.00")<br><br>DLO: W-1054mm(41.50") H-1663mm(65.50") |

| SPECIFICATION             | PRODUCT RATING   |
|---------------------------|--|
| <b>TAS 201/202/203-94</b> | <b>Design Pressure: 2394 Pa (50 psf)</b><br><b>Negative Design Pressure: 2394 Pa (50 psf)</b><br><b>Large Missile Impact Rated</b> |

Product Tested By: National Certified Testing Laboratories  
 Report No: NCTL-210-3913-01  
 Expiration Date: **August 30, 2025**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
**4794 George Washington Memorial Highway**  
**Hayes, VA 23072**  
**Tel: (804) 684-5124**  
**Fax: (804) 684-5122**