

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013760.06-R1  
**DATE:** 09/05/2019  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1  
**REVISION DATE:** 10/26/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Premium Vinyl V-4500 w/Flush Handle</b> <b>Multi-Slide Sliding Patio Door</b> <b>(Fin or Flange Installation)</b>  Configuration: OX or XX Glazing: Insulating Glass (Tempered)  Frame: W-1829mm(72") H-2032mm(80") Panel: W-940mm(37") H-1962mm(77.25") DLO: W-730mm(28.75") H-1753mm(69")

SPECIFICATION	PRODUCT RATING
<b>TAS 202-94</b>	<b>Design Pressure: ±3112 Pa (65 psf)</b> <b>Positive Design Pressure: 3112 Pa (65 psf)</b> <b>Negative Design Pressure: 3352 Pa (70 psf)</b> Water Penetration Resistance Test Pressure: 504 Pa (10.5 psf)

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-4150-01  
Expiration Date: **June 30, 2030**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)