

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015728.01
DATE: 08/14/2023
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "F4500 Folding Impact Doors" Fiberglass Glazed Folding Doors Configuration: XXX Glazing: IG-1/8" Tempered Glass/0.090" PVB Kuraray Interlayer/1/8" Tempered Glass/1/8" Tempered Glass Frame: W-2711mm(106.75") H-2013mm(79.25") Panel: W-908mm(35.75") H-1943mm(76.50") DLO: W-670mm(26.38") H-1743mm(68.63")

SPECIFICATION	PRODUCT RATING
ASTM E1886-19 ASTM E1996-20 AAMA 506-16	Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2640 Pa (55 psf) Wind Zone 3 - Missile Level D Large Missile Impact Rated

Product Tested By: Intertek, LLC
Report No: Q2461.01-301-47
Expiration Date: June 30, 2027

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com