

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015729.03
DATE: 03/13/2023
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "F4500 Swinging Door" Fiberglass Glazed Outswing Direct Side-Hinged Door Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-1816mm(71.50") H-1984mm(78.13") Panel: W-876mm(34.50") H-1949mm(76.75") DLO: W-670mm(26.38") H-1740mm(68.50")

SPECIFICATION	PRODUCT RATING
TAS 202-94 (Structural Only)	DP +50/-55 Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-310-23-019
Expiration Date: **February 28, 2027**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com