

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015729.04  
DATE: 05/09/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: JELD-WEN  
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "F4500 Swinging Door"</b> <b>Fiberglass Glazed Outswing</b> <b>Direct Glazed Side-Hinged Door</b>  Configuration: XX Glazing: IG-1/8" Tempered Glass/1/8" Annealed Glass/0.090" Kuraray PVB Interlayer/1/8" Annealed Glass  Frame: W-1816mm(71.5") H-1984mm(78.13") Panel: W-876mm(34.5") H-1949mm(76.75") DLO: W-670mm(26.5") H-1740mm(68.5")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>CSA A440S1-17</b> <b>ASTM E1886-12/13a</b> <b>ASTM E1996-12a/14a/17</b>	<b>Class R-PG50 1816 x 1984*(72 x 78*)-SHD</b> <b>Design Pressure: 2400 Pa (50 psf)</b> <b>Negative Design Pressure: 2640 Pa (55 psf)</b> Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) <b>Canadian Air Infiltration/Exfiltration Level: A2</b> <b>Wind Zone 3 - Missile Level D</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-310-23-006/NCTL-310-23-008  
Expiration Date: **January 31, 2027**

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015729.05  
DATE: 07/13/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: JELD-WEN  
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "F4500 Swinging Door"</b> <b>Fiberglass Glazed Inswing</b> <b>Side-Hinged Door</b>  Configuration: XX Glazing: IG-1/8" Tempered Glass/1/8" Tempered Glass/0.090" Kuraray PVB Interlayer/1/8" Tempered Glass  Frame: W-1816mm(71.5") H-2019mm(79.5") Panel: W-876mm(34.5") H-1949mm(76.75") DLO: W-667mm(26.25") H-1740mm(68.5")

SPECIFICATION	PRODUCT RATING
<b>AAMA 506-16</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>CSA A440S1-17</b> <b>ASTM E1886-19</b> <b>ASTM E1996-20</b>	<b>Class R-PG50 1816 x 1984(72 x 80)-LW SHD</b> <b>Design Pressure: 2400 Pa (50 psf)</b> <b>Negative Design Pressure: 2640 Pa (55 psf)</b> Water Penetration Resistance Test Pressure: 0 Pa (0 psf) <b>Canadian Air Infiltration/Exfiltration Level: A2</b> <b>Wind Zone 3 - Missile Level D</b>

Product Tested By: Intertek, PLC  
Report No: P9225.01-301-47/NCTL-310-23-008  
Expiration Date: **March 31, 2027**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)