

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015901.01
DATE: 11/14/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33913	Series "279.043" Vinyl Double Hung Window (w/Fin Frame/Flange Frame/Equal Leg Frame) Configuration: X/X Glazing: Insulating Glass (Annealed) Frame: W-1324mm(52.13") H-1905mm(75") Sash: W-1233mm(48.56") H-937mm(36.88") DLO: W-1159mm(45.63") H-860mm(36.06")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC-PG60 1324 x 1905 (52 x 75)-H Design Pressure: ±2880 Pa (±60 psf) Water Penetration Resistance Test: 440 Pa (9.19 psf) w/Sill Extension 10005139 Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, PLC
Report No: P9404.02-109-47
Expiration Date: July 31, 2027

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "M.D.", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com