WINDOW & DOOR MANUFACTURERS ASSOCIATION

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC. Administrative Management Systems, Inc.

MarvinMfr ID:407PO Box 100For more Information visit www.amscert.com401 State Ave N.Website:Warroad, MN 56763TEL:218-386-1430

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
407-H-1168.04	Ultimate Sliding French Door 2-1/4 inch G2 OXO CN120100	101/I.S.2/A440-11	Class LC-PG40; Size Tested 3715mm (146-1/4") x 3099mm (122") Type-SGD; DP +40/-40 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A3	3715mm (146-1/4")	3099mm (122")	P2290.01-201-47 R1	8/7/2023	9/15/2032
407-H-1168.05	Ultimate Sliding French Door 2-1/4 inch G2 OXO CN120100	101/I.S.2/A440-17	Class LC-PG40; Size Tested 3715mm (146-1/4") x 3099mm (122") Type-SGD; DP +40/-40 psf; Water Test Press 290Pa (6.06psf); Can. Air Infil/Exfil. Level=A3	3715mm (146-1/4")	3099mm (122")	P2290.01-201-47 R1	8/7/2023	9/15/2032

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

Luc John McFee, VP of Certification Programs, WDMA Hallmark By: An Lucas L. Wenzel. Authorized Representative. AMS

Program Sponsor: Window and Door Manufacturers Assoc 330 N. Wabash Avenue, Suite 2000 Chicago, IL 60611 TEL (312)673-4828 www.wdma.com Program Administrator: Administrative Management Systems, Inc. PO Box 730, 205 West Main Sackets Harbor, NY 13685 TEL (315)646-2234 staff@amscert.com