

Hallmark® Certificate of Conformance and License (CCL)



Marvin
PO Box 100
401 State Ave N.
Warroad, MN 56763

Mfr ID: 407
For more Information visit www.amscert.com
Website: www.marvin.com
TEL: 218-386-1430

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
407-H-1168.39	Ultimate Sliding French Door 2-1/4 inch G2 IZ3 OXXO CN160100	101/I.S.2/A440-11	Class LC-PG50; Size Tested 4851mm (191") x 3099mm (122") Type-SD; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	4851mm (191")	3099mm (122")	P8912.01-201-47	10/12/2023	3/23/2033
407-H-1168.40	Ultimate Sliding French Door 2-1/4 inch G2 IZ3 OXXO CN160100	101/I.S.2/A440-17	Class LC-PG50; Size Tested 4851mm (191") x 3099mm (122") Type-SD; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	4851mm (191")	3099mm (122")	P8912.01-201-47	10/12/2023	3/23/2033
407-H-1168.41	Ultimate Sliding French Door 2-1/4 inch G2 IZ3 OXXO CN160100	ASTM E-1996 17/ASTM E-1886 13a	DP +50/-50 psf, Missile D, Wind Zone 3	4851mm (191")	3099mm (122")	P8912.02-201-47	10/12/2023	4/13/2033

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com