

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016189-R1  
DATE: 05/20/2024  
CERTIFICATION PROGRAM: Structural  
COMPANY: JELD-WEN  
CODE: 1822-1  
REVISION DATE: 06/06/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "La Cantina Doors"</b> <b>Aluminum Fixed Door</b>  Configuration: O Glazing: Insulating Glass (Tempered)  Frame: W-1890mm(74.41") H-3658mm(144.02") DLO: W-1800mm(70.87") H-3560mm(140.16")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-22</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class LC-PG50 1890 x 3658 (74 x 144)-FD</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> <b>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)</b>

Product Tested By: Intertek, PLC  
Report No: Q9102.01-303-44/W-2122  
Expiration Date: **January 31, 2028**

Administrator's Signature: \_\_\_\_\_ 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)