

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016190-R1
DATE: 05/20/2024
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 06/06/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "La Cantina Doors" Aluminum Dual Outswing Side Hinged Doors Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-2515mm(99") H-3048mm(120") Panel: W-1241mm(48.86") H-2984mm(117.48") DLO: W-1113mm(43.82") H-2870mm(112.99")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17	Class LC-PG40 2515 x 3048 (99 x 120)-SHD Design Pressure: 1920 Pa (40 psf) Positive Design Pressure: 1920 Pa (40 psf) Negative Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Intertek, PLC
Report No: Q9099.01-303-44/W-2122
Expiration Date: **January 31, 2028**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com