

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI016190.01-R1  
**DATE:** 05/20/2024  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1  
**REVISION DATE:** 06/06/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Series "La Cantina Doors"</b> <b>Aluminum Dual Outswing</b> <b>Side Hinged Doors</b>  Configuration: XX Glazing: Insulating Glass (Tempered)  Frame: W-2280mm(89.76") H-3658mm(144")  Panel: W-1115mm(43.89") H-3586mm(141.18")  DLO: W-991mm(39.03") H-3481mm(137.05")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-22</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class LC-PG35 2280 x 3658 (90 x 144)-SHD</b> <b>Design Pressure: 1680 Pa (35 psf)</b> <b>Positive Design Pressure: 1680 Pa (35 psf)</b> <b>Negative Design Pressure: 1680 Pa (35 psf)</b> <b>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)</b>

Product Tested By: Intertek, PLC  
Report No: Q9100.01-303-44/W-2122  
Expiration Date: **January 31, 2028**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)