



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

Elevate Windows & Doors, LLC
1850 Westpark Dr., Suite 100
Grand Prairie, TX 75050

This authorization is based on the successful completion of tests and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED		
AAMA/WDMA/CSA 101/I.S.2/A440-17 R-PG60-1206x1816 (48x72)-FW	AAMA 506			
COMPANY AND CODE	Missile Level: D Rating: +60/-60, 48x72 Wind Zone: 3	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED
Elevate Windows & Doors, LLC Code: ELE	Rating above conforms to requirements of: ASTM E1886 and E1996	22086	IMPACT FIXED (PVC)(O)(OG) (INS 0.090" PVB LAM GL) (ASTM)	FRAME 1206 mm x 1816 mm (48" x 72")

This Certification will expire **April 1, 2029** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

Construction Consulting Laboratory

Report No: **CCL 24-143**

Date of Report: **September 16, 2024 (Revised October 29, 2024)**

Date Test Completed: **April 1, 2024**

Missile Impact Test & Report By:


Construction Consulting Laboratory

Report No: **CCL 24-143**

Date of Report: **September 16, 2024 (Revised Oct. 29, 2024)**

Date Test Completed: **April 1, 2024**

Evaluated for Certification: **November 1, 2024**


Associated Laboratories, Inc.

Authorized for Certification: **November 1, 2024**


Fenestration and Glazing Industry Alliance
1900 East Golf Road Schaumburg, IL 60173



(Validator / Operations Administrator)