



AUTHORIZATION FOR PRODUCT CERTIFICATION

**Simonton Windows
1 Cochrane Ave.
Pennsboro, WV 26415**

Attn: Tina Jenkins Seese

The product described below is hereby approved for listing in the next issue of the AAMA Certified Products Directory. The approval is based on successful completion of tests, and the reporting to the Administrator of the results of tests, accompanied by related drawings, by an AAMA Accredited Laboratory.

1. The listing below will be added to the next published AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-08 R-PG55-1346x1930 (53x76)-H Negative Design Pressure = -60 psf	AAMA 506				
COMPANY	Missile Level: D Rating: +55/-60, 53x76 Wind Zone: 4 Rating above conforms to requirements of: ASTM E1886 and E1996	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
Simonton Windows Code: SIM		12486	07-09/07-20 STORM BREAKER PLUS DH (PVC) (X/X) (OG) (INS LAM GL) (MODIF) (REINF) (TILT) (ASTM)	<u>FRAME(mm)</u> 1346 x 1930 (4'5" x 6'4")	<u>SASH(mm)</u> 1267 x 946 (4'2" x 3'1")

2. This Certification will expire **November 6, 2017** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

3. Structural Test & Report By:

Architectural Testing, Inc.

Report No: **D0965.01-501-47**

Date of Report: **November 15, 2013**

Missile Impact Test & Report by:

Architectural Testing, Inc.

Report No: **D8120.01-109-47; Ref. D0964.01-501-47**

Date of Report: **June 10, 2014; November 15, 2013**

Validated for Certification

Associated Laboratories, Inc.

Authorized for Certification

American Architectural Manufacturers Association

Date: **November 22, 2013**
Revised: **October 12, 2015**
Cc: AAMA
SBS