

AAMA CERTIFICATION PROGRAM



AUTHORIZATION FOR PRODUCT CERTIFICATION

Simonton Windows
1 Cochrane Ave.
Pensboro, WV 26415

Attn: Tina Jenkins Seese

The product described below is hereby approved for listing in the next issue of the AAMA Certified Products Directory. The approval is based on successful completion of tests, and the reporting to the Administrator of the results of tests, accompanied by related drawings, by an AAMA Accredited Laboratory.

1. The listing below will be added to the next published AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-08 R-PG50*-914x1880 (36x74)-H	AAMA 506				
COMPANY AND PLANT LOCATION	Missile Level: C Rating: +50/-50, 36x74 Wind Zone: 2 Rating above conforms to requirements of: ASTM E1886 and E1996	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
Simonton Windows Code: SIM		8355	42-19 DOUBLE HUNG (PVC) (X/X) (OG) (INS LAM GL) (TILT) (REINF) (ASTM)	<u>FRAME(mm)</u> 914 x 1880 (3'0" x 6'2")	<u>SASH(mm)</u> 860 x 940 (2'10" x 3'1")

2. This Certification will expire **September 14, 2019 (extended from September 14, 2016 per AAMA 103-15)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

3. Structural Test & Report By:

Architectural Testing, Inc.

Report No: **B7589.01-501-47; Ref. A3993.01-501-47**

Date of Report: **March 23, 2012; October 7, 2010**

Missile Impact Test & Report by:

Architectural Testing, Inc.

Report No: **B7583.01-501-47 Rev.1**

Date of Report: **March 23, 2012 (Revised June 11, 2012)**

Validated for Certification

Associated Laboratories, Inc.

Authorized for Certification

American Architectural Manufacturers Association

Date: **March 23, 2012**
Revised: **December 30, 2015**
Cc: AAMA
SBS