



AUTHORIZATION FOR PRODUCT CERTIFICATION

**Simonton Windows
1 Cochrane Dr.
Pennsboro, WV 26415**

Attn: Tina Seese

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-08 R-PG55-1346x1930 (53x76)-H Negative Design Pressure = -60 psf	AAMA 506				
COMPANY AND CODE	Missile Level: D Rating: +55/-60, 53x76 Wind Zone: 4	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
Simonton Windows Code: SIM	Rating above conforms to the requirements of: ASTM E1886 and E1996	11730	07-09/07-20 STORMBREAKER PLUS DH (PVC)(X/X)(OG) (INS 0.105" PVB LAM GL) (MODIF)(REINF)(TILT) (ASTM)	<u>FRAME (mm)</u> 1346 x 1930 (4'5" x 6'4")	<u>SASH (mm)</u> 1267 x 946 (4'2" x 3'1")

This Certification will expire **November 6, 2022 (extended from November 6, 2017 per AAMA 103-15)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

Architectural Testing, Inc.

Report No: **D0965.01-501-47**

Date of Report: **November 15, 2013**

Missile Impact Test & Report By:

Architectural Testing, Inc.

Report No: **D8120.01-109-47; ref. D0964.01-501-47**

Date of Report: **June 10, 2014; November 15, 2013**

Evaluated for Certification: **April 26, 2017**

Associated Laboratories, Inc.

Authorized for Certification: **April 26, 2017**

American Architectural Manufacturers Association