(Validator / Operations Administrator)

AAMA
CERTIFICATION PROGRAM

AUTHORIZATION FOR PRODUCT CERTIFICATION

Simonton Windows
1 Cochrane Dr.
Pennsboro, WV 26415

Attn: Tina Seese

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-08 R-PG65*-940x1930 (37x76)-H	**AAMA 506**				
COMPANY AND CODE	Missile Level: **D** Rating: **+65/-65, 37x76** Wind Zone: **4** Rating above conforms to the requirements of: **ASTM E1886 and E1996**	**CPD NO.**	**SERIES MODEL & PRODUCT DESCRIPTION**	**MAXIMUM SIZE TESTED**	
Simonton Windows Code: SIM		**16421**	**07-09/07-20 STORMBREAKER PLUS DH (PVC)(X/X)(OG) (INS 0.105" PVB LAM GL) (MODIF)(REINF)(TILT) (ASTM)**	**FRAME (mm)** **940 x 1930** **(3'1" x 6'4")**	**SASH (mm)** **857 x 946** **(2'10" x 3'1")**

This Certification will expire **August 6, 2022 (extended from August 6, 2017 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

Architectural Testing, Inc. & Farabaugh Engineering & Testing, Inc.

Report No: **D0296.01-501-47; ref. T259-10**

Date of Report: **August 20, 2013; August 3, 2010**

Missile Impact Test & Report By:

Architectural Testing, Inc.

Report No: **D8118.01-109-47; ref. D0962.01-501-47**

Date of Report: **June 9, 2014; November 15, 2013**

Evaluated for Certification: **April 26, 2019**

Associated Laboratories, Inc.

Authorized for Certification: **April 26, 2019**

American Architectural Manufacturers Association

JGS/JTS

ACP-14 (Rev. 6/16)