

**AAMA
CERTIFICATION PROGRAM**



AUTHORIZATION FOR PRODUCT CERTIFICATION

Simonton Windows
1 Cochrane Ave.
Pennsboro, WV 26415

Attn: Tina Jenkins

The product described below is hereby approved for listing in the next issue of the AAMA Certified Products Directory. The approval is based on successful completion of tests, and the reporting to the Administrator of the results of tests, accompanied by related drawings, by an AAMA Accredited Laboratory.

1. The listing below will be added to the next published AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-08 R-PG55-1346x660 (53x26)-AP	AAMA 506	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
COMPANY AND PLANT LOCATION	Missile Level: D Rating: +55/-55, 53x26 Wind Zone: 4 Rating above conforms to requirements of: ASTM E1886 and E1996				
Simonton Windows Code: SIM		7924	08-09/08-20 STORM BREAKER PLUS AWNING (PVC) (X) (OG) (INS TEMP/PVB LAM GL) (MODIF) (ASTM)	FRAME(mm) 1346 x 660 (4'5" x 2'2")	VENT(mm) 1302 x 616 (4'3" x 2'0")

2. This Certification will expire **August 2, 2020 (extended from August 2, 2015 per AAMA 103-15)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

3. Structural Test & Report By:

Architectural Testing, Inc.

Report No: **B2264.01-501-47**

Date of Report: **September 28, 2011**

Missile Impact Test & Report by:

PRI Construction Materials Technologies / Architectural Testing, Inc.

Report No: **SIMO-003-03-02; Ref. B3413.01-109-47 Rev. 2**

Date of Report: **February 5, 2015; December 22, 2011 (Revised 5/29/12)**

*****ALL CERTIFIED PRODUCTS MUST BE PRODUCED WITH TEMPERED AND LAMINATED GLASS.*****

Validated for Certification

Associated Laboratories, Inc.

Authorized for Certification

American Architectural Manufacturers Association

Revised: **August 17, 2015**

Cc: AAMA

SBS