

AAMA CERTIFICATION PROGRAM



AUTHORIZATION FOR PRODUCT CERTIFICATION

Simonton Windows
1 Cochrane Ave.
Pennsboro, WV 26415

Attn: Tina Seese

The product described below is hereby approved for listing in the next issue of the AAMA Certified Products Directory. The approval is based on successful completion of tests, and the reporting to the Administrator of the results of tests, accompanied by related drawings, by an AAMA Accredited Laboratory.

1. The listing below will be added to the next published AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-08 R-PG55-1346x660 (53x26)-AP	AAMA 506	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
COMPANY AND PLANT LOCATION	Missile Level: D Rating: +55/-55, 53x26 Wind Zone: 4 Rating above conforms to requirements of: ASTM E1886 and E1996	11479	08-09/08-20 STORM BREAKER PLUS AWNING (PVC) (X) (OG) (INS PVB LAM GL) (MODIF) (ASTM)	FRAME(mm) 1346 x 660 (4'5" x 2'2")	VENT(mm) 1302 x 616 (4'3" x 2'0")
Simonton Windows Code: SIM					

2. This Certification will expire **August 2, 2021 (extended from August 2, 2016 per AAMA 103-15)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

3. Structural Test & Report By:

Architectural Testing, Inc.

Report No: **B2264.01-501-47**

Date of Report: **September 28, 2011**

Missile Impact Test & Report by:

PRI Construction Materials Technologies / Architectural Testing, Inc.

Report No: **SIMO-003-03-02; Ref. D7965.01-109-47, D0957.01-109-47**

Date of Report: **February 5, 2015; June 9, 2014, September 19, 2013**

Validated for Certification

Associated Laboratories, Inc.

Authorized for Certification

American Architectural Manufacturers Association

Date: **September 28, 2013**

Revised: **May 19, 2016**

Cc: AAMA

SBS