

AAMA CERTIFICATION PROGRAM



AUTHORIZATION FOR PRODUCT CERTIFICATION

Simonton Windows
1 Cochrane Dr.
Pennsboro, WV 26415

Attn: Tina Seese

The product described below is hereby approved for listing in the next issue of the AAMA Certified Products Directory. The approval is based successful completion of tests, and the reporting to the Administrator of the results of tests, accompanied by related drawings, by an AAMA Accredited Laboratory.

1. The listing below will be added to the next published AAMA Certified Products Directory.

| SPECIFICATIONS | | RECORD OF PRODUCT TESTED | | | |
|---|---|--------------------------|--|---|---|
| AAMA/WDMA/CSA 101/I.S.2/A440-08 R-PG50-3639x2013 (143x79)-SD | AAMA 506 | | | | |
| COMPANY AND CODE | Missile Level: D Rating: +50/-50, 143x79 Wind Zone: 4 | CPD NO. | SERIES MODEL & PRODUCT DESCRIPTION | MAXIMUM SIZE TESTED | |
| Simonton Windows Code: SIM | Rating above conforms to the requirements of: ASTM E1886 and E1996 | 10223 | 11-11 SGD (PVC)(OXO)(OG) (INS TEMP/SGP LAM GL) (MODIF)(REINF)(ASTM) | FRAME (mm) 3639 x 2013 (11'11" x 6'7") | PANEL (mm) 1245 x 1934 (4'1" x 6'4") |

2. This Certification will expire **October 31, 2021 (extended from October 31, 2016 per AAMA 103-15)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

3. Structural Test & Report By:

Architectural Testing, Inc.

Report No: **C3517.01-501-47**

Date of Report: **January 11, 2013**


Missile Impact Test & Report By:

Architectural Testing, Inc.

Report No: **C4265.01-109-47**

Date of Report: **January 21, 2013**

Validated for Certification


 Associated Laboratories, Inc.

Date: **May 26, 2016**

Cc: AAMA

JGS

ACP-14 (Rev. 1/11)

Authorized for Certification


 American Architectural Manufacturers Association