

# Hallmark® Certificate of Conformance and License (CCL)




VELUX America LLC  
450 Old Brickyard Rd  
PO Box 5001  
PO Box 5001  
Greenwood, SC 29649

*Mfr ID:* 426  
*For more Information visit* [www.amscert.com](http://www.amscert.com)  
*Website:* [www.veluxusa.com](http://www.veluxusa.com)  
*TEL:* 864-941-5309

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
426-H-701.27	FCM 4646 (or smaller) Impact + [06, 16 or TZR/TZRL/TZRQ 014 1A00]	101/I.S.2/A440-17	Class PG-PG50; Size Tested 1308mm x 1308mm Type-SKG; DP +120/-80 psf; Water Test Press 720Pa (15.04psf); Can. Air Infil/Exfil. Level=Fixed	1308mm	1308mm	NCTL-210-4208-1	4/9/2021	2/23/2031
426-H-701.28	FCM 4646 (or smaller) Impact + [06, 16 or TZR/TZRL/TZRQ 014 1A00]	101/I.S.2/A440-11	Class PG-PG50; Size Tested 1308mm x 1308mm Type-SKG; DP +120/-80 psf; Water Test Press 720Pa (15.04psf); Can. Air Infil/Exfil. Level=Fixed	1308mm	1308mm	NCTL-210-4208-1	4/9/2021	2/23/2031
426-H-701.31	FCM 4646 (or smaller) Impact + [06, 16 or TZR/TZRL/TZRQ 014 1A00]	ASTM E1996-14a/ ASTM E-1886-13a	DP +50/-50 psf, Missile D, Wind Zone 4	1308mm	1308mm	NCTL-210-4208-1	4/9/2021	2/23/2031
426-H-701.32	FCM 4646 (or smaller) Impact + [06, 16 or TZR/TZRL/TZRQ 014 1A00]	TAS 201/202/203-94	TAS 202: DP +125/-80 psf DP +50/-50 psf, Large Missile	1308mm	1308mm	NCTL-210-4208-01A	4/9/2021	2/23/2031

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

*By:*  John McFee, VP of Certification Programs, WDMA Hallmark

*By:*  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:  
Window and Door Manufacturers Assoc  
330 N. Wabash Avenue, Suite 2000  
Chicago, IL 60611  
TEL (312)673-4828 [www.wdma.com](http://www.wdma.com)

Program Administrator:  
Administrative Management Systems, Inc.  
PO Box 730, 205 West Main  
Sackets Harbor, NY 13685  
TEL (315)646-2234 [staff@amscert.com](mailto:staff@amscert.com)