

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006799-R3  
DATE: 11/11/2006  
CERTIFICATION PROGRAM: Structural  
COMPANY: Masonite  
CODE: 703-1  
REVISION DATE: 11/21/2014

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Masonite International Corporation</b> <b>1955 Powis Road</b> <b>West Chicago, IL 60185</b>	<b>Series "Transom/Fixed"</b> <b>Wood/PVC Composite Fixed Window</b>  Configuration: O  Glazing: Insulating Glass (Tempered)  Frame: W-2134mm(84") H-1219mm(48") DLO: W-2096mm(82.5") H-1168mm(46")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA 101/LS.2/NAFS-02</b> <b>ASTM F588-97</b>	<b>F-R60 2134 x 1219 (84 x 48)</b> <b>FER-Passed</b>

Product Tested By: Architectural Testing, Inc.  
Report No: ATI-010-47015.01  
Expiration Date: **December 31, 2020**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122