

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009126-R4
DATE: 10/08/2007
CERTIFICATION PROGRAM: Structural
COMPANY: Glass Craft
CODE: 1157-1
REVISION DATE: 04/30/2018

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Glass Craft Door Corporation 2002 Brittmoore Houston, TX 77043-2209	Series "Six Lite TDL Arch Top Hardwood" Double Glazed In-Swing & Out-Swing Doors (w/Surface Bolts) Configuration: X/X True Divided Lites: Six Lite Panel Glazing: Insulating Glass (Tempered) Frame: W-1880mm(74") H-2515mm(99") Panel: W-914mm(36") H-2438mm(96") Lite: W-229mm(9") H-432mm(17")

SPECIFICATION	PRODUCT RATING
ASTM E330-02	Design Pressure: +45.0/-40.0 psf Qualifies Configuration: X/XX

Product Tested By: Certified Testing Laboratories
Report No: CTLA-1743W-4 & 1743W-5
Expiration Date: **September 30, 2020**

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122