

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009125-R9
DATE: 10/08/2007
CERTIFICATION PROGRAM: Structural
COMPANY: Glass Craft
CODE: 1157-1
REVISION DATE: 01/03/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Glass Craft Door Corporation 2002 Brittmoore Houston, TX 77043-2209	Series "Portobello/Estancia Arch Top Hardwood" Double Glazed In-Swing Doors (w/Surface Bolts) Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-1880mm(74") H-2515mm(99") Panel: W-914mm(36") H-2438mm(96") Lite: W-559mm(22") H-1422mm(56")

SPECIFICATION	PRODUCT RATING
ASTM E330/E330M-14	Design Pressure: +50.0/-50.0 psf

Product Tested By: Certified Testing Laboratories
Report No: CTLA-1743W/W-2108
Expiration Date: September 30, 2026

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com