



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

Lippert Components, Inc. dba Kinro Windows
3501 County Road 6 East
Elkhart, IN 46514

Attn: Rob Luter

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-08 & A440S1-09 R-PG50*-1175x1549 (46x61)-H					
COMPANY AND CODE	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION		MAXIMUM SIZE TESTED	
Lippert Components, Inc. dba Kinro Windows Code: KIN	14722	9750 SH (PVC)(O/X)(OG)(INS GL) (MODIF)(REINF)(TILT) (ASTM)		<u>FRAME</u> 1175 mm x 1549 mm (3'10" x 5'1")	<u>SASH</u> 1130 mm x 759 mm (3'8" x 2'6")
Design Pressure (psf): +50/-50	Design Pressure (Pa): +2400/-2400	Water Test Pressure (Pa): 360		Canadian Air Infiltration/Exfiltration: A3	


This Certification will expire **November 18, 2025 (extended from November 18, 2020 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Product Tested and Reported by: **Intertek-ATI**

Report No.: **F2608.01-109-44**

Date of Report: **December 2, 2015 (Revised December 10, 2015)**

Evaluated for Certification: **August 11, 2020**


Associated Laboratories, Inc.

Authorized for Certification: **August 11, 2020**


Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)