

AAMA CERTIFICATION PROGRAM

An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION



Lippert Components, Inc. dba Kinro Windows 3501 County Road 6 East Elkhart, IN 46514

Attn: Rob Luter

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

| SPECIFICATION | | | | | | | |
|---|---------------------------|--|----------------------------------|---|---|--|--|
| AAMA/WDMA/CSA 101/I.S.2/A44 & A440S1-09 R-PG40*-2769x1727 (109x68)- | | RECORD OF PRODUCT TESTED | | | | | |
| COMPANY AND CODE | CPD NO. | PD NO. SERIES MODEL & PRODUCT DESCRIPTION | | MAXIMUM SIZE TESTED | | | |
| Lippert Components, Inc. dba Kinro Windows 14 Code: KIN | | 9730 TRIPLE SH (PVC)(O/X.O/X.O/X)(OG) (INS GL)(MODIF)(REINF) (TILT)(ASTM) | | FRAME 2769 mm x 1727 mm (9'1" x 5'8") | | <u>SASH</u> 870 mm x 848 mm (2'10" x 2'9") | |
| Design Pressure (psf): +40/-40 | Design Pre (Pa): +1920 | | Water Test Pressure (Pa): 290 | | Canadian Air Infiltration/Exfiltration: A3 | | |

This Certification will expire **April 24, 2025 (extended from April 24, 2020 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Product Tested and Reported by: Intertek-ATI

Report No.: E7176.01-602-44

Date of Report: May 4, 2015

(Validator / Operations Administrator)

ACP-04 (Rev. 1/20)

Evaluated for Certification: January 28, 2020

Associated Laboratories, Inc.

Authorized for Certification: January 28, 2020

Fenestration and Glazing Industry Alliance