



**AAMA CERTIFICATION PROGRAM**  
An FGIA Product Certification Program



**AUTHORIZATION FOR PRODUCT CERTIFICATION**

**Lippert Components, Inc. dba Kinro Windows**  
3501 County Road 6 East  
Elkhart, IN 46514

**Attn: Rob Luter**

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

|   |  |   |   |  |  |
|---|--|---|---|--|--|
| <b>SPECIFICATION</b>  |  | <b>RECORD OF PRODUCT TESTED</b>   |   |  |  |
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-11<br/>&amp; A440S1-09<br/>R-PG40*-1175x2134 (46x84)-H<br/>Negative Design Pressure = -50 psf</b> |  |   |   |  |  |
| <b>COMPANY AND CODE</b>   | <b>CPD NO.</b>                               | <b>SERIES MODEL &amp; PRODUCT DESCRIPTION</b>   | <b>MAXIMUM SIZE TESTED</b>                            |  |  |
| <b>Lippert Components, Inc.<br/>dba Kinro Windows<br/>Code: KIN</b>   | 16443  | <b>9730 SH W/TRANSOM<br/>(PVC)(O/O/X)(OG)(INS GL)<br/>(MODIF)(REINF)(TILT)<br/>(ASTM)</b> | <b>FRAME</b><br>1175 mm x 2134 mm<br>(3'10" x 7'0")   | <b>SASH</b><br>1130 mm x 743 mm<br>(3'8" x 2'5") |  |
| <b>Design Pressure<br/>(psf): +40/-50</b>   | <b>Design Pressure<br/>(Pa): +1920/-2400</b> | <b>Water Test Pressure<br/>(Pa): 290</b>  | <b>Canadian Air<br/>Infiltration/Exfiltration: A3</b> |  |  |

This Certification will expire **March 23, 2027 (extended from March 23, 2022 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Product Tested and Reported by: **National Certified Testing Laboratories**

Report No.: **NCTL-110-19892-1**

Date of Report: **March 24, 2017 (Revised April 6, 2017)**

Evaluated for Certification: **October 15, 2021**

Associated Laboratories, Inc.

Authorized for Certification: **October 15, 2021**

Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)