



**AAMA CERTIFICATION PROGRAM**  
An FGIA Product Certification Program



**AUTHORIZATION FOR PRODUCT CERTIFICATION**

**Lippert Components, Inc. dba Kinro Windows**  
3501 County Road 6 East  
Elkhart, IN 46514

**Attn: Rob Luter**

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

<b>SPECIFICATION</b>		<b>RECORD OF PRODUCT TESTED</b>			
AAMA/WDMA/CSA 101/I.S.2/A440-11 & A440S1-09 R-PG40*-1842x1994 (73x79)-H					
<b>COMPANY AND CODE</b>		<b>CPD NO.</b>	<b>SERIES MODEL &amp; PRODUCT DESCRIPTION</b>	<b>MAXIMUM SIZE TESTED</b>	
Lippert Components, Inc. dba Kinro Windows Code: KIN		11247	9730 TWIN SH W/TRANSOM (PVC)(O/O/X.O/X)(OG) (INS GL)(REINF)(TILT) (ASTM)	<u>FRAME</u> 1842 mm x 1994 mm (6'1" x 6'7")	<u>SASH</u> 870 mm x 746 mm (2'10" x 2'5")
<b>Design Pressure (psf): +40/-40</b>	<b>Design Pressure (Pa): +1920/-1920</b>		<b>Water Test Pressure (Pa): 290</b>	<b>Canadian Air Infiltration/Exfiltration: A3</b>	


This Certification will expire **July 11, 2027 (extended from July 11, 2022 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Product Tested and Reported by: **Architectural Testing, Inc.**

Report No.: **C8168.01-109-44**

Date of Report: **July 30, 2013**

Evaluated for Certification: **October 29, 2021**

  
Associated Laboratories, Inc.

Authorized for Certification: **October 29, 2021**

  
Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)

ACP-04 (Rev. 2/20)