



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

Lippert Components, Inc. dba Kinro Windows
3501 County Road 6 East
Elkhart, IN 46514

Attn: Rob Luter

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-11 & A440S1-09 R-PG40*-1842x1994 (73x79)-H Negative Design Pressure = -50 psf					
COMPANY AND CODE	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED		
Lippert Components, Inc. dba Kinro Windows Code: KIN	11246	9730 TWIN SH W/TRANSOM (PVC)(O/O/X.O/X)(OG) (INS GL)(MODIF)(REINF) (TILT)(ASTM)	FRAME 1842 mm x 1994 mm (6'1" x 6'7")	SASH 870 mm x 746 mm (2'10" x 2'5")	
Design Pressure (psf): +40/-50	Design Pressure (Pa): +1920/-2400	Water Test Pressure (Pa): 290	Canadian Air Infiltration/Exfiltration: A3		

This Certification will expire **July 11, 2027 (extended from July 11, 2022 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.


Product Tested and Reported by: **Architectural Testing, Inc.**

Report No.: **C8168.03-109-44**

Date of Report: **July 30, 2013**

**NOTE: ALL CERTIFIED WINDOWS MUST BE GLAZED WITH
TEMPERED GLASS IN THE TRANSOM.**

Evaluated for Certification: **October 29, 2021**


 Associated Laboratories, Inc.

Authorized for Certification: **October 29, 2021**


 Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)