

Compliance Statement FL39615
December 5, 2023

Evaluator: Lucas A. Turner, FL PE #58201, 2428 Old Natchez Trc. Trl., Camden, TN

Florida Product Approval Reference: FL39615

Product Description: 07-09, 07-10 & 07-20 5500 Reflections, PerfeXion Platinum, 6000EX w/SafePoint Double Hung- Impact Missile C


Manufacturer: Simonton Windows, 5020 Weston Parkway, Suite 300, Cary, NC 27513

Statement of Compliance: I have reviewed the above-listed product and Florida Product Approval, previously approved for 2020 Florida Building Code (FBC) compliance, per the requirements of FAC Product Approval Rule Chapter 61G20-3.007(f) for Self-Affirmation.

The new edition of the code, 8th Edition (2023) FBC, does not require a material or substantive change of this approved product or its installation. The testing standards / standard dates listed in this approval, AAMA 506-16, AAMA/WDMA/CSA 101/I.S.2/A440-11, ASTM E 1886-13a, and ASTM E 1996-14a, are also compliant with the 8th Edition (2023) FBC and are therefore valid and acceptable under the new code.

This product complies with the requirements of the 8th Edition (2023) Florida Building Code outside the High Velocity Hurricane Zone.

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Simonton Windows or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



12/5/2023
Lucas A. Turner, P.E.
FL PE #58201