

Evaluation Report 640C
February 5, 2016

Product Description: Series SD-8700, FD-8750, SLT-8710 PVC Swinging Door, Non Impact, 3'x8' nominal panel size max.

Manufacturer: Custom Window Systems, Inc. 1900 SW 44th Ave, Ocala, FL 34474

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 5th Edition (2014) Florida Building Code outside the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:

- 1) This report, prepared by Lucas A. Turner, P.E., at 1239 Jabara Ave., North Port, FL
- 2) Approval drawing CWS-640C, signed and sealed by Lucas A. Turner, P.E.
- 3) Test Reports NCTL-210-3761-3 from National Certified Testing Laboratories, Orlando, FL signed and sealed by Gerard J. Ferrara, P.E.
 - a. Testing Performed: AAMA/WDMA/CSA 101/I.S.2/A440-05
- 4) Supplemental Calculations to support CWS-640C, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to approval document CWS-640C.

Limitations of Use: This product:

- May be used in up to 79" x 97" XX sizes, 40" x 97" X sizes, and 36 3/16" x 97" Sidelite sizes, with glass types and max. glass daylight sizes as shown in CWS-640C
- Achieves design pressures as shown in CWS-640C
- Is nonimpact and requires the use of shutters in windborne debris regions
- May not be used in the High Velocity Hurricane Zone
- Requires Quanex (Mikron) white rigid PVC framing as shown in CWS-640C
- Anchors indicated in CWS-640C shall be pan or hex head type and shall have a head or washer (integrated or separate) diameter of 0.420" min.

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Custom Window Systems or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



LT

2/5/2016

Lucas A. Turner, P.E.
FL PE #58201

Lucas A. Turner
2016-02-05
10:47:05:00