

2428 Old Natchez Trace Trail Camden, TN 38320 Ph. 941-380-1574 FBPE C.O.A. #29779

> **Evaluation Report 839C** August 06, 2020

**Product Description:** Series SD-8700-8750, PVC Swinging Door, LM Impact, 4'x8' nominal panel size max., Design Pressure +/-60 p.s.f.

Manufacturer: Custom Window Systems, Inc. 1900 SW 44<sup>th</sup> Ave, Ocala, FL 34474

**Statement of Compliance:** This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 7<sup>th</sup> Edition (2020) Florida Building Code including the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

## **Technical Documentation:**

- 1) This report, prepared by Lucas A. Turner, PE, at 2428 Old Natchez Trc Trl, Camden, TN
- 2) Approval drawing CWS-839C, signed and sealed by Lucas A. Turner, P.E.
- 3) Test Reports NCTL-210-3694-1, -1A, from National Certified Testing Laboratories, Orlando, FL signed and sealed by Gerard J. Ferrara, P.E., with testing performed: TAS 201/202/203 1994, AAMA/WDMA/CSA 101/I.S.2/A440-2005, and ASTM E 1886/1996 2002/2005
- 4) Supplemental Calculations to support CWS-839C, signed and sealed by Lucas A. Turner, P.E.

**Installation:** Units must be installed according to approval document CWS-839C.

## **Limitations of Use:** This product:

- May be used in up to 99" x 96 3/4" XX sizes, with glass types and max. glass daylight sizes as shown in CWS-839C, and achieves design pressures of  $\pm -60$  p.s.f.
- Is Large Missile Impact Resistant and does not require the use of shutters
- May be used in the High Velocity Hurricane Zone
- Anchors indicated in CWS-839C shall be pan or hex head type and shall have a head or washer (integrated or separate) diameter of 0.420" min.
- Requires Kuraray SentryGlas Interlayer per Miami-Dade NOA 17-0808.02<sup>†</sup>
- Requires Quanex or Veka white rigid PVC framing per Miami-Dade NOA 17-0206.10<sup>†</sup> or 17-0228.04<sup>†</sup>

<sup>†</sup> I have evaluated the interlayer and framing materials in these Kuraray, Quanex, and Veka NOAs and find that they comply with the requirements of the 7<sup>th</sup> Ed. (2020) Florida Building Code for use in this product.

**Certification of Independence:** I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Custom Window Systems or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.

