



NOTES FOR ALL METHODS:  
 1. THIS PRINT IS FOR STRUCTURAL PERFORMANCE ONLY. FOR FLASHING & SEALING INSTRUCTIONS, REFER TO THE INSTALLATION INSTRUCTIONS.  
 2. SHIMS—PLACE A SHIM WITHIN 4-6 INCHES OF EACH CORNER AND SPACE ALL OTHERS EVENLY A MAXIMUM OF 15" APART.  
 3. IF CHEMICALLY TREATED LUMBER IS USED FOR BUCK MATERIAL, FASTENERS INTO THE BUCK MUST BE A MINIMUM OF 0.90 OZ/FT<sup>2</sup> ZINC HOT DIPPED GALVANIZED OR STAINLESS STEEL TYPE 304 OR 316.

UNIT	MAX FRAME SIZE	DP RATING
UL AWN	56 X 47 1/8	+50/-50
UL AWN NF	56 X 47 1/8	+50/-50

ITEM NO	REF NO	DESCRIPTION
5	-----	1 1/2" GALV ROOF NAILS
4	-----	WOOD BUCK BY OTHERS
3	-----	#8 X 2.5" WOOD SCREW
2	-----	SHIM
1	-----	#8 X 3.000 WOOD SCREW

CATEGORY:  
CASEMENT

UNIT TYPE:  
UAWNNF, UAWN

UNSPECIFIED TOLERANCES	
DECIMALS: XX ± .03 XXX ± .012	ANGLE DEG: ± .5
LINEAL: + .125 - .000	FAB LINEAL: ± NA
MATERIAL: NA	

**MARVIN** RESEARCH & DEVELOPMENT

COLLECTION: ULTIMATE

DWG TYPE: INSTALLATION  
 DESCRIPTION: INSTALLATION FL# 10323

CHK:	SIZE: B	CLASS: MISC	DWG NO: 00127103
APP:	SCALE: NA	DATE: 12/31/20	DWG BY: KOMPELIEN, SARA

SHEET: 1 OF 1